



材料暨工程實驗室-台中

建築材料樣品試驗報告



報告編號：TB-23-02289-1

C-23-05327

頁數：1 OF 1

報告日期：112年06月14日

工程名稱：自測
 承包商：----
 委託單位：廣德地板企業有限公司
 供料廠商：----
 樣品名稱：複合木質地板
 送驗人員：廣德地板企業有限公司-劉勝宗
 收件日期：112年04月26日
 試驗日期：112年04月26日~112年06月14日
 備註：1.以上資料(送驗人員、會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供
 2.除非另有說明，此報告結果僅對測試之樣品負責
 未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗結果		# CNS 11342:2014 規範值	試驗方法
	單邊未剝離長度 / 單邊長度 (mm)			
浸水剝離試驗	1-1	77.95 / 77.95	試片同一膠合層，各側面之未剝離長度應超過總長之2/3以上	CNS 11342:2014
	1-2	78.61 / 78.61		
	1-3	77.86 / 77.86		
	1-4	78.75 / 78.75		
	2-1	76.19 / 76.19		
	2-2	78.60 / 78.60		
	2-3	76.34 / 76.34		
	2-4	78.70 / 78.70		
	3-1	74.12 / 74.12		
	3-2	78.88 / 78.88		
	3-3	73.96 / 73.96		
	3-4	78.90 / 78.90		
	4-1	77.25 / 77.25		
	4-2	76.21 / 76.21		
	4-3	77.49 / 77.49		
	4-4	76.92 / 76.92		


- 註：1.樣品描述：木地板
 2.本試驗報告之試驗地點同實驗室地址
 3.本試驗報告取代 TB-23-02289 C-23-05327，原試驗報告作廢，報告修改日期112年08月17日，修改試驗結果之敘述

產品相關資訊如下：

產品名稱：複合木質地板
 產品型號：GD03(10.7 mm,F1,櫟木紋)
 主要材料或構件：牛皮紙裝飾層*0.7 mm、合板*9 mm、酚醛樹脂*130g/米平方、PE靜音墊*1 mm
 產品厚度：10.7 mm
 統一編號：70470102
 委託單位地址：新北市板橋區四川路一段286巷47號
 委託單位負責人：陳其昌
 負責人身份證號：P121791***

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準


 報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.